

PHOTOVOLTAICS IN ROOFING

This Technical Bulletin Volume 57, finalized in November 2010 by the Canadian Roofing Contractors' Association (CRCA), was originally published in the Spring/Summer 2011 issue of Roofing Canada and is reprinted here with permission.

As a result of the desire to achieve energy self-sufficiency with “clean energy,” solar energy production has increased an average of more than 20% each year since 2002, making it the world’s fastest-growing energy technology. Government subsidies and the possibility of selling excess production back to the power grid have led to building owners to either install their own power systems or lease their roofs to companies marketing and operating solar-electric photovoltaic (PV) systems. Low-slope roofs, which represent a significant portion of the urban footprint, are often viewed as an ideal platform for solar installations. Usually free of obstructions, with good exposure to the sun, rooftop solar installations represent an efficient use of space. However, many factors must be considered before deciding whether a roof is a suitable candidate. If not carefully planned, not only can the hoped-for return on investment in solar quickly evaporate, it can result, instead, in significant financial loss

and jeopardize the performance of the roof on which it was installed.

There are two common types of PV systems designed for rooftop installations: rigid, rack-mounted arrays and integrated PV systems adhered directly to the roof surfaces. This bulletin discusses the rack-mounted systems, as current technology and climatic conditions have limited the use of the adhered systems in Canada.

HOW IT WORKS

PV power is derived from cells that contain a solar PV material that converts solar radiation into direct current (DC) electricity. Solar cells use sunlight to produce DC electricity, which can be used to power equipment or be stored in a battery to provide power when the PVs are not generating electricity. By using an inverter to convert the DC to alternating current (AC), these systems may be used for grid-connected power generation. This allows the building owner to generate and use solar power during the day and deliver excess power directly to the utility grid. Although PV works best when

there is direct sunlight, some PV technologies generate power whenever any light is available to the panel.

MOUNTING TECHNIQUES

There are three basic ways by which rack-mounted solar panels can be secured to the roof. The first relies on penetrations and connections to structural framing. This method allows for reduced dead loads to the structure and the ability for the designer to specify live loads. It provides the greatest number of options for tilting the array, resulting in the greatest energy yield. This method also assures a level platform for the solar panels.

The second method relies on ballasting to secure the panels. The weights of the array, racking system, and additional ballast material are used to prevent wind uplift and dislocation from other loads. The advantage of this method is that fewer roof penetrations have to be made watertight. The disadvantages include an increased dead load; the tilt of the arrays may be limited, depending on wind uplift loads; and it

may be difficult to obtain a flat platform for the arrays, depending on the roof's drainage patterns.

The third option is a hybrid, which consists of a limited number of connections through the roof to the structural framing, combined with ballasting material. Where this method is used, the general rule of thumb is that the fewer the connections, the more ballast required, and vice versa.

RISKS AND HAZARDS

FM Global has identified several important risk factors in the evaluation of rooftop solar installations. These include:

- Combustibility,
- Wind uplift and securement,
- Roof loading,
- Drainage, and
- Natural-hazards resistance.

COMBUSTIBILITY

All PV cells should be tested and listed by a recognized testing laboratory. Their fire resistance should be at least as robust as the roof they are being mounted upon to comply with most building and fire codes. The most widely recognized standard for PV panels is UL 1703, *Standard for Flat-Plate Photovoltaic Modules and Panels*. Referenced within this standard is UL 790, *Standard Test Methods for Fire Tests of Roof Coverings*, which is used to determine the fire resistance performance of roof coverings exposed to simulated fire sources originating from outside a building on which the coverings are installed. The test is similar to CAN/ULC-S107-10, *Standard Methods of Fire Tests of Roof Coverings*, referenced in the National Building Code of Canada.

A PV array roof installation may change the way the roof reacts under fire conditions. This is due to the proximity of the panels to the roof, resulting in thermal feedback, and the wind tunnel effect between the panel and the roof that may occur under certain conditions.

ROOF LOADING

For new systems, the additional load of solar panels should be considered when developing the structural design for the building. For retrofit applications, it is critical to assure that the roof system has the carrying capacity for the panels and will withstand any additional loads. Loads to be considered include dead loads from the PV array and asso-

ciated equipment, as well as live loads such as wind, snow, rain, and seismic events.

Wind loading is another significant consideration. Edges and corners of roof structures have greater wind loads than the center of the roof, requiring additional structural considerations closer to the roof edge. Wind loading can have a major impact on the PV array characteristics, including the tilt angle, array location, and securement method. The test protocol in CSA Standard A123.2, *Standard Test Method for the Dynamic Wind Uplift Resistance of Membrane Roofing Systems*, has been used successfully to determine the wind resistance of PV systems under dynamic loading conditions.

Snow loads are another variable load consideration. PV arrays mounted at an angle to the roof surface distribute snow in a variety of ways. Snow will tend to drift along the roof and collect along the backside of the modules, increasing the load on the roof. It is also possible for the array to collect snow during a storm and then shed that snow once the sun comes out. This will increase the point loading on the front side of the array.

Seismic loads must also be factored into the structural calculations.

DRAINAGE

Drainage must also be considered in the design of a rooftop solar installation. The PV system must not interfere with the roof's drainage. Conduits, rack penetrations, and other PV components can impede drainage and compromise the roof's performance.

NATURAL-HAZARDS RESISTANCE

The impact resistance of solar panels should also be considered. Hail or windborne debris may damage panels that are not sufficiently robust, necessitating expensive shutdowns and replacement.

ROOF CONDITION

PV systems should be installed only on roofs that are in good condition. It makes no sense to install a 30-year PV system on a roof with five or ten years of serviceable life remaining. When it comes time to reroof, the entire PV system may have to be removed to facilitate the reroofing process, and then be reinstalled. On existing buildings, this means verifying the age of the roof and the remaining length of any warranties. It also means surveying the roof for stress, damage, or other existing problems. Areas of ponding water or roof edge and flashing details have to be rectified before a PV system can be installed. Many reputable roofing system manufacturers are partnering with solar integrators and now offer PV-ready assemblies that meet the rigid performance requirements of a roof suitable for a PV installation.

Wherever possible when roof mounting solar panels, the original roofing contractor or another manufacturer-approved roofing contractor should be contacted to verify that the roof is in good condition before the work begins. The contractor and roofing systems manufacturer should be present during the entire installation to ensure there is no damage to the roof and that all work has been carried out in accordance with the manufacturers' instructions and good roofing practice. Upon completion of the PV installation, a thorough inspection of the roof should be carried out. Building owners should be aware that any additions or alterations to the roof, including adding equipment without the prior consent of the contractor and/or system manufacturer,



may result in increased warranty costs or void the roof warranty entirely.

Another important consideration is the roof wear and tear resulting from the actual PV installation and postinstallation maintenance. Any roof considered as a platform for PV must be designed to withstand an increased level of construction and maintenance traffic. The surfacing, membrane system, and insulation must have adequate mechanical strength to withstand the traffic they will be subjected to. There should always be walkways designed into the PV array. This is helpful for both the installation crew as well as future maintenance technicians. These personnel will likely have tool belts and tool boxes in tow, so there should be some walkways wide enough for this level of activity. People should be able to pass one another without damaging the array. Regardless of the space between rows, it is good practice to provide paths so that people are not tempted to make shortcuts through the array.

PV rack-mounted systems should be designed to facilitate roof maintenance,


repair, and even reroofing. This means providing sufficient clearance of the PV components from the roof, walls, roof penetrations, and other PV components to allow for the repair, removal, and replacement of the roofing components as may be required.

It must be recognized that the installation of a solar array on a roof will substantially impact the cost of future maintenance due to the increased number of penetrations and rooftop equipment components. If roof repairs are required, it may necessitate that a qualified PV technician or electrician oversees the repair to ensure the integrity of the PV system. Conversely, a roofing technician should always be present when the PV system is serviced or repaired to ensure the roof is not damaged.

CONCLUSION

The good news is that many reputable roofing system manufacturers are partnering with solar integrators and now offer PV-ready assemblies that meet the rigid performance requirements of a roof suitable for a PV installation. The roofing industry is

actively interacting with the PV industry and the architectural community to develop standards and best practices for solar rooftop installations. Through roofing associations and organizations such as the Center for Environmental Innovation in Roofing, our industry is heavily involved in disseminating information regarding study, design, and installation of rooftop PV systems. All personnel installing rooftop PVs should be trained in the proper care and functioning of the roof. Some roofing organizations and roofing contractors are now providing training to their personnel in how to properly waterproof connections and penetrations and how to work under and around roof-mounted PV systems.

Rooftop PVs should only be installed on assemblies that are suitable platforms for the solar system and the mounting method being used. The roof assembly under a PV system should have a service life equal to or longer than the expected service life of the PV system. This should help to minimize service disruptions during the life of the PV system. 



The key to our Garden Roof® is our Monolithic Membrane 6125®, a seamless rubberized asphalt membrane with a 45+ year track record for critical water-proofing and roofing applications world-wide.



From concept to completion

American Hydrotech's Garden Roof® Assembly has set the standard by which all other green roofs are measured. Our Total Assembly Warranty provides owners with single source responsibility from the deck up. This is peace of mind that only American Hydrotech can offer.

To learn more about the American Hydrotech Garden Roof Assembly, please call **800.877.6125** or visit us online at www.hydrotechusa.com.

American Hydrotech, Inc. | 303 East Ohio | Chicago, IL 60611 | 800.877.6125 | www.hydrotechusa.com



© 2010 Garden Roof is a registered trademark of American Hydrotech, Inc.